


Border solar modules for M300-60-b GG LEVEL



3337.0154 Swiss Premium M150-6x5-b GG LEVEL

| | |
|-----------------------------|---------------|
| Nominal power (Pmpp) | 150 Wp |
| Nominal voltage (Umpp) | 16.2 V |
| Nominal current (Impp) | 9.26 A |
| Open circuit voltage (Uoc) | 19.4 V |
| Short circuit current (Isc) | 9.61 A |
| Number of cells (matrix) | 30 (6x 5) |
| Dimensions (LxWxH) ±3.0 mm | 1100x868x8 mm |
| Modular dimensions (LxW) | 1016x873 mm |
| Weight | 16.7 kg |




3337.0155 Swiss Premium M150-3x10-b GG LEVEL

| | |
|-----------------------------|---------------|
| Nominal power (Pmpp) | 150 Wp |
| Nominal voltage (Umpp) | 16.2 V |
| Nominal current (Impp) | 9.26 A |
| Open circuit voltage (Uoc) | 19.4 V |
| Short circuit current (Isc) | 9.61 A |
| Number of cells (matrix) | 30 (3x 10) |
| Dimensions (LxWxH) ±3.0 mm | 620x1695x8 mm |
| Modular dimensions (LxW) | 536x1700 mm |
| Weight | 18.4 kg |



3337.0156 Swiss Premium M75-3x5-b GG LEVEL

| | |
|-----------------------------|--------------|
| Nominal power (Pmpp) | 75 Wp |
| Nominal voltage (Umpp) | 8.1 V |
| Nominal current (Impp) | 9.26 A |
| Open circuit voltage (Uoc) | 9.7 V |
| Short circuit current (Isc) | 9.61 A |
| Number of cells (matrix) | 15 (3x 5) |
| Dimensions (LxWxH) ±3.0 mm | 620x868x8 mm |
| Modular dimensions (LxW) | 536x873 mm |
| Weight | 9.4 kg |



3337.0210 Special module LEVEL with cells

Customized production with electrically active solar cells
Shape and size differs from standard. Production according to customer requirement.

E-mail: info@megasol.ch
Hotline: +41 62 919 90 90
www.megasol.ch



Border modules are electrically compatible with the corresponding basic module (60 solar cells).
For technical reasons of production, despite utmost care, the surface properties and optical colour effect may vary from the basic module.

STC (Standard Test Conditions): irradiance 1000 W/m², cell temperature 25°C, AM 1.5
Measuring tolerances ±3 % (Pmpp); ±10 % (Umpp, Impp, Uoc, Isc)



Note: The instructions in the installation manual must be strictly complied with. Further information about approved utilization of products can be found in the installation manual or can be requested from the technical service.

Megasol partner

Subject to errors and technical modifications.
© Megasol Energy Ltd | Version: 09/2017